

नियम १२, ११० (२) आणि ११४, ११६ (२) आणि ११७ (१) (२) व ३ पहा.

- सर्वसाधारण पावती -
यवतमाळ नगर परिषद

पुस्तक क्र. 97

31

श्री. महर्षि विद्या मेढी, महर्षि नगर, यवतमाळ

नं.

यांचे कडून

रुपये ५०००/-

मुलगीरंग हमाणपु

अक्षरी

पाच हजार रुपये केवळ

बदल

मिळाले

दिनांक १४/०६/२०२२.

लिपीकाची सही
रोकडवहीत नोंद केली पृष्ठ क्रमांक
लेखापाल/रोखपाल



Xirpud

प्राधिकृत अधिकार्यांची सही

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

जिल्हा आरोग्य प्रयोगशाळा, यवतमाळ

दुरध्वनी क्र. २४२९४६

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

E-mail-dphlyvt@gmail.com

प्रति,

पाठविणाऱ्यांचे पत्र क्रमांक व दिनांक

प्रयोगशाळा संदर्भ क्रमांक

:- महर्षि निव्या मंदिर, यवतमाळ.

:- 17.01.22

:- 356

नमुना घेतल्याचा दिनांक

:- 17.01.22

नमुना पोहचल्याची दिनांक

:- 4

परिक्षण सुरु केल्याची दिनांक

:- 1

अ. क्र.	नमुन्याचे विवरण.	परीक्षणाचे निष्कर्ष		इतर अभिप्राय
		प्रति१०० मि.लि.नमुन्यातील संभाव्य सूक्ष्मजंतुची संख्या		
		कोलीफॉर्म	थर्मोटॉलरंट केलिफॉर्म	
१)	नळ - महर्षि निव्या मंदिर, यवतमाळ. गाव - मोहा. ता. - यवतमाळ.	भोळा पेसा जास्त	०३	<u>पिण्यास योग्य आहे.</u>

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात प्रमाण क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.

जा.क्र. :-

185

दिनांक :-

20.01.22

अहवाल ईमेलने कळविल्याचा दिनांक

प्रत सादर :

- १ शल्य चिकित्सक, जिल्हा रुग्णालय, जिल्हा यवतमाळ
- २ जिल्हा आरोग्य अधिकारी, जि.प. यवतमाळ.....
- ३ गटविकास अधिकारी, पंचायत समिती.....
- ४ तालुका वैद्यकीय अधिकारी, तालुका.....

मुख्य अणुजीव शास्त्रज्ञ
जिल्हा आरोग्य प्रयोगशाळा
यवतमाळ

District Public Health Laboratory, Yavatmal.

E-mail ID: dphlyvt@gmail.com

Phone :07232-242946

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Dt. of Collection:- 17/01/2022 Dt. of Receipt:- 17/01/2022 -Dt. of Exam:- 17/01/2022 onwards
(All the Analytical Results are in mgs. / liter except pH & Turbidity)

SR.NO	TEST PARAMETER	Tap ① maharshi vidya mandir, ytl	BIS Specifications 10500 : 2012(Edn.2.2) Normal Values	
			Desirable Limits	Permissible Limits
1	Physical Appearance	clear	--	--
2	Odour	odourless	Unobjectionable	--
3	Turbidity (N.T.U.)	0.56	1	5
4	P ^H Value	7.4	6.5 to 8.5	No Relaxation
5	Fluoride (as F)	0.77	1	1.5
6	Nitrates (as NO ₃)	10	45	No Relaxation
7	Total Dissolved Solids	383	500	2000
8	Iron (as Fe)	0.08	0.3	No Relaxation
9	Chlorides (as Cl)	100	250	1000
10	Total Hardness (as CaCO ₃)	284	200	600
11	Alkalinity (as CaCO ₃)	110	200	600
12	Permanent Hardness(As CaCO ₃)	174	-	-

- This Report is restricted only for the sample/s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.

REMARKS

✓ A) Water Sample No. 61 is chemically fit/potable for drinking purposes on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purposes only after proper disinfection and ascertaining it's bacteriological quality.

✗ B) Sample No. Contain/s..... is/ are more than the Desirable limit as per BIS specifications. However, it can be used for drinking purposes only in the absence of alternate source and only after proper treatment & disinfection and ascertaining it's bacteriological quality.

✗ C) Sample No. Contains /s..... is/are more than the Permissible limit as per BIS specifications. Hence this / these water source(s) is / are Unfit for drinking purposes.

HEALTH SERVICES


LR. No - 21 / 194 /2022

Date: - 21.1.2022

Forwarded With Compliments To:-

✓ maharshi vidya
mandir, yavatmal
vill. moha

With reference to letter no. Dated :-


Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal.



Yavatmal, Municipal Council Yavatmal

D.N/YNP/SID/ 353 /2022
date-25/1/2022

**//SAFE DRINKING WATER/SANITARY
CONDITION CERTIFICATE //**

This is certified that an inspection team from nagar parishad Yavatmal Dist Yavatmal inspected the maharishi vidya mandir main compus bargaon deam road maharishi nagar moha Yavatmal 445001 on date 25/1/2022 and found that the **maharishi vidya mandir Yavatmal** has provided service connection (1/2"dia)for drinking water purpose and according to regional government laboratory Yavatmal provided safe drinking water facilities for this school and also nagar parishad Yavatmal provided that sanitary facility to maharishi vidya mandir Yavatmal. There is alos a sufficient separate and clean toilet arrangement for boys and girls students.

This certificate is valid upto 27/01/2023



Palvesky
Chief Officer
Municipal Council Yavatmal

To,
Principal
maharishi vidya mandir
main compus bargaon deam road
maharishi nagar moha Yavatmal 445001